

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW19989**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-WC-1, Center Hallway

Collect Date: 09/26/2016
Collect Time: 06:15
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW19991**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-WC-2, outside cafeteria

Collect Date: 09/26/2016
Collect Time: 06:14
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW19992**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-WC-3, inside cafeteria

Collect Date: 09/26/2016
Collect Time: 06:14
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW19993**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-4, C1 sink

Collect Date: 09/26/2016
Collect Time: 06:22
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW19995
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-5, C2 sink

Collect Date: 09/26/2016
Collect Time: 06:24
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.003, 0.015, mg/L, SM3113B, MN, 11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW19996**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-6, C3 sink

Collect Date: 09/26/2016
Collect Time: 06:25
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW19997**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-7, C4 sink

Collect Date: 09/26/2016
Collect Time: 06:26
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW19998**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-8, C5 sink

Collect Date: 09/26/2016
Collect Time: 06:27
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW19999**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-9, C6 sink

Collect Date: 09/26/2016
Collect Time: 06:28
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20000**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-10, C7 sink

Collect Date: 09/26/2016
Collect Time: 06:29
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20001**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-11, C100

Collect Date: 09/26/2016
Collect Time: 06:32
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20002**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-FC-12, Faculty Lounge

Collect Date: 09/26/2016
Collect Time: 06:16
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.009	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20003**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-NS-13, Nurse Sink

Collect Date: 09/26/2016
Collect Time: 06:18
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20004**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-KC-14, Kitchen island

Collect Date: 09/26/2016
Collect Time: 06:05
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.007	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20005
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-KC-15, Kitchen rear

Collect Date: 09/26/2016
Collect Time: 06:06
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.010	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
P	Sample preserved at lab	Z	Analysis is not state-certified	C	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20006**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-KC-16, Kitchen

Collect Date: 09/26/2016
Collect Time: 06:07
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.10	0.015	X	mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20007**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-KC-17, Handwash

Collect Date: 09/26/2016
Collect Time: 06:07
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.070	0.015	X	mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20008
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-KC-18, Kettle - right

Collect Date: 09/26/2016
Collect Time: 06:08
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.003, 0.015, M+, mg/L, SM3113B, MN, 11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20009**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-KC-19, Kettle - left

Collect Date: 09/26/2016
Collect Time: 06:09
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20010**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-21, D3 bubbler

Collect Date: 09/26/2016
Collect Time: 06:46
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.007	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20011**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-22, D4 bubbler

Collect Date: 09/26/2016
Collect Time: 06:45
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20012**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-23, D5 bubbler

Collect Date: 09/26/2016
Collect Time: 06:44
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1

Sample ID: **AW20013**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-24, D6 bubbler

Collect Date: 09/26/2016
Collect Time: 06:42
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
P	Sample preserved at lab	Z	Analysis is not state-certified	C	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20014**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-25, D7 bubbler

Collect Date: 09/26/2016
Collect Time: 06:41
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20015**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-26, D100 classrm sink

Collect Date: 09/26/2016
Collect Time: 06:39
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20016**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-FC-27, Faculty Room D102

Collect Date: 09/26/2016
Collect Time: 06:37
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20017**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-29, D9

Collect Date: 09/26/2016
Collect Time: 06:55
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.009	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20018**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-30, D10

Collect Date: 09/26/2016
Collect Time: 06:53
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20019**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-31, D11 bubbler

Collect Date: 09/26/2016
Collect Time: 00:00
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20020**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-DW-32, B1

Collect Date: 09/26/2016
Collect Time: 07:11
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.010	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20021**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-DW-33, B2

Collect Date: 09/26/2016
Collect Time: 00:00
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20022**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-DW-34, B3

Collect Date: 09/26/2016
Collect Time: 07:07
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.011	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20023**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-DW-35, B4

Collect Date: 09/26/2016
Collect Time: 00:00
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20024
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-DW-36, B5

Collect Date: 09/26/2016
Collect Time: 00:00
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.007, 0.015, mg/L, SM3113B, MN, 11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20025**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-DW-37, B6

Collect Date: 09/26/2016
Collect Time: 00:00
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20026**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-DW-38, B7

Collect Date: 09/26/2016
Collect Time: 00:00
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20027**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-CF-39, B100

Collect Date: 09/26/2016
Collect Time: 06:59
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20028**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-FC-40, Faculty Sink

Collect Date: 09/26/2016
Collect Time: 00:00
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20029**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-DW-41, A1 bubbler

Collect Date: 09/28/2016
Collect Time: 07:31
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.016	0.015	X	mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20030**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-DW-42, A2 bubbler

Collect Date: 09/28/2016
Collect Time: 07:27
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20031**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-DW-43, A3 bubbler

Collect Date: 09/26/2016
Collect Time: 07:17
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20032**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-DW-44, A4 bubbler

Collect Date: 09/26/2016
Collect Time: 07:17
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.006	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20033**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-DW-46, A6 bubbler

Collect Date: 09/28/2016
Collect Time: 07:27
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.009	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20034**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-DW-47, A7 bubbler

Collect Date: 09/26/2016
Collect Time: 07:16
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20035**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-CF-48, A100 sink

Collect Date: 09/26/2016
Collect Time: 07:15
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20036**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-49, Kitchen bathrm

Collect Date: 09/26/2016
Collect Time: 06:10
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.012	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20037**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-51, Men's - Fac. next to Nurse

Collect Date: 09/26/2016
Collect Time: 06:17
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20038**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-52, Women's Rm - inside faculty

Collect Date: 09/26/2016
Collect Time: 06:17
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.006	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20039**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-53, Women's - across frm nurse

Collect Date: 09/26/2016
Collect Time: 06:21
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20040**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-54, Nurse's bathrm

Collect Date: 09/26/2016
Collect Time: 06:19
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20041**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-55, Men's rm - across frm nurse

Collect Date: 09/26/2016
Collect Time: 06:21
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20042**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-56, C1 bubbler

Collect Date: 09/26/2016
Collect Time: 06:23
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.010	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20043
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-57, C2 bubbler

Collect Date: 09/26/2016
Collect Time: 06:24
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.003, 0.015, mg/L, SM3113B, MN, 11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20044**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-58, C3 bubbler

Collect Date: 09/26/2016
Collect Time: 06:25
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20045**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-59, C4 bubbler

Collect Date: 09/26/2016
Collect Time: 06:26
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
 (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
 MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20046**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-60, C5 bubbler

Collect Date: 09/26/2016
Collect Time: 06:27
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20047
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-61, C6 bubbler

Collect Date: 09/26/2016
Collect Time: 06:29
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.004, 0.015, mg/L, SM3113B, MN, 11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20048**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-DW-62, C7 bubbler

Collect Date: 09/26/2016
Collect Time: 06:29
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20049**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-63, C100 bath

Collect Date: 09/26/2016
Collect Time: 06:33
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20050**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-64, C101 sink

Collect Date: 09/26/2016
Collect Time: 06:34
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20051**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-C-BF-65, C102

Collect Date: 09/26/2016
Collect Time: 06:34
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20052**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-FC-66, D101

Collect Date: 09/26/2016
Collect Time: 06:38
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/13/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20054**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-BF-67, D100

Collect Date: 09/26/2016
Collect Time: 06:39
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20055**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-68, D7 sink

Collect Date: 09/26/2016
Collect Time: 06:41
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20056
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-69, D6 sink

Collect Date: 09/26/2016
Collect Time: 06:42
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.002, 0.015, mg/L, SM3113B, MN, 11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20058**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-70, D5 sink

Collect Date: 09/26/2016
Collect Time: 06:44
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20059**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-71, D4 sink

Collect Date: 09/26/2016
Collect Time: 06:45
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20060**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-72, D3 sink

Collect Date: 09/26/2016
Collect Time: 06:46
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20061**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-73, D2 bubbler

Collect Date: 09/26/2016
Collect Time: 06:45
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.012	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20062**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-74, D2 sink

Collect Date: 09/26/2016
Collect Time: 06:48
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20063**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-75, D1 sink

Collect Date: 09/26/2016
Collect Time: 06:49
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20065
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-76, D12 bubbler

Collect Date: 09/26/2016
Collect Time: 06:50
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.007	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
P	Sample preserved at lab	Z	Analysis is not state-certified	C	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20066**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-77, D12 sink

Collect Date: 09/26/2016
Collect Time: 06:50
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20067**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-78, D11 sink

Collect Date: 09/26/2016
Collect Time: 06:52
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20068**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-79, D10 sink

Collect Date: 09/26/2016
Collect Time: 06:53
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20069**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-CF-80, D9 sink

Collect Date: 09/26/2016
Collect Time: 06:55
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20071**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-BF-81, B102 bathrm

Collect Date: 09/26/2016
Collect Time: 06:58
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20072**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-BF-82, B100 bathrm

Collect Date: 09/26/2016
Collect Time: 06:59
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20073**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-CF-83, B7 sink

Collect Date: 09/26/2016
Collect Time: 07:00
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20074**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-CF-84, B6 sink

Collect Date: 09/26/2016
Collect Time: 07:02
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20075**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-CF-85, B5 sink

Collect Date: 09/26/2016
Collect Time: 07:04
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20076
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-CF-86, B4 sink

Collect Date: 09/26/2016
Collect Time: 07:05
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.005, 0.015, mg/L, SM3113B, MN, 11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20077**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-BF-87, B4 bathrm

Collect Date: 09/26/2016
Collect Time: 07:05
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.015	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20078**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-BF-88, B5 bathrm

Collect Date: 09/26/2016
Collect Time: 07:05
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.028	0.015	X	mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20079**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-CF-89, B3 bathrm

Collect Date: 09/26/2016
Collect Time: 07:07
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20081**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-CF-90, B2 sink

Collect Date: 09/26/2016
Collect Time: 07:10
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20082**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-B-CF-91, B1 sink

Collect Date: 09/26/2016
Collect Time: 07:11
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20084
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-BF-92, A100 bathrm

Collect Date: 09/26/2016
Collect Time: 07:15
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.005, 0.015, mg/L, SM3113B, MN, 11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20085**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-CF-93, A7 sink

Collect Date: 09/26/2016
Collect Time: 07:16
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20086**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-CF-94, A5 sink

Collect Date: 09/26/2016
Collect Time: 07:17
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20087
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-CF-95, A4 sink

Collect Date: 09/26/2016
Collect Time: 07:20
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.002, 0.015, mg/L, SM3113B, MN, 11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20089**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-CF-96, A6 sink

Collect Date: 09/28/2016
Collect Time: 07:27
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.015	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20090**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-CF-97, A3 sink

Collect Date: 09/28/2016
Collect Time: 07:30
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20091**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-CF-98, A2 sink

Collect Date: 09/28/2016
Collect Time: 07:27
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:


X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20093**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-CF-99, A1 sink

Collect Date: 09/28/2016
Collect Time: 07:31
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: AW20094
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-WC-100, outside gym near A1

Collect Date: 09/28/2016
Collect Time: 07:32
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.002, 0.015, mg/L, SM3113B, MN, 11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20095**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-WC-101, outside gym near A11

Collect Date: 09/28/2016
Collect Time: 07:33
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20097**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-BF-102, A11 bathrm

Collect Date: 09/28/2016
Collect Time: 07:34
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.039	0.015	X	mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20099**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-BF-104, Girls locker rm A-14

Collect Date: 09/28/2016
Collect Time: 07:35
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1

Sample ID: AW20101
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-A-BF-105, Boys locker rm A-14

Collect Date: 09/28/2016
Collect Time: 07:35
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.007, 0.015, mg/L, SM3113B, MN, 11/14/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/15/2016 Page 1 of 1
Sample ID: **AW20102**
Date Received: 09/29/2016
Time Received: 10:00
Date Finalized: 11/15/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 360 State Street, Hudson
Sample Pt: JLE-D-DW-106, D1 bubbler

Collect Date: 09/26/2016
Collect Time: 06:49
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source:
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/14/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.