

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25153**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-101 Mens BR by Art 136

Collect Date: 10/25/2016
Collect Time: 06:34
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25154**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-102 Mens BR by Art 136

Collect Date: 10/25/2016
Collect Time: 06:34
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:


- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25155**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-103 Womens BR 114

Collect Date: 10/25/2016
Collect Time: 06:35
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25156**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-104 Womens BR 114

Collect Date: 10/25/2016
Collect Time: 06:35
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
 (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25157**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-CF-105 Art Rm 115

Collect Date: 10/25/2016
Collect Time: 06:37
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25158**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-CF-106 Art Rm 115

Collect Date: 10/25/2016
Collect Time: 06:37
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25159**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-CF-107 Band Rm

Collect Date: 10/25/2016
Collect Time: 06:38
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1

Sample ID: AW25160
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-108 Mens Rm by Band Rm

Collect Date: 10/25/2016
Collect Time: 06:39
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.006, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25161**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-109 Ladies Rm by Band Rm

Collect Date: 10/25/2016
Collect Time: 06:40
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25162**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-110 Girls BR Jr High

Collect Date: 10/25/2016
Collect Time: 06:41
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.035	0.015	X	mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:


- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25163**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-111 Girls BR Jr High Lobby

Collect Date: 10/25/2016
Collect Time: 06:42
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25164
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-112 Girls BR Jr High Lobby

Collect Date: 10/25/2016
Collect Time: 06:42
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25165**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-113 Boys BR Jr High Lobby

Collect Date: 10/25/2016
Collect Time: 06:43
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25166**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-114 Boys BR Jr High Lobby

Collect Date: 10/25/2016
Collect Time: 06:43
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25167**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-115 Boys BR Jr High Lobby

Collect Date: 10/25/2016
Collect Time: 06:43
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25168**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-116 Jr High Locker Rm Boys

Collect Date: 10/25/2016
Collect Time: 06:44
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25169**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-117 Jr High Locker Rm Boys

Collect Date: 10/25/2016
Collect Time: 06:44
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25170**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-118 Jr High Locker Rm Boys

Collect Date: 10/25/2016
Collect Time: 06:44
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:


- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25171**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-119 Jr High Locker Rm Girls

Collect Date: 10/25/2016
Collect Time: 06:45
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25172**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-120 Jr High Locker Rm Girls

Collect Date: 10/25/2016
Collect Time: 06:45
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25173**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-121 Jr High Locker Rm Girls

Collect Date: 10/25/2016
Collect Time: 06:46
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.007	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25174
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-122 Mens A102

Collect Date: 10/25/2016
Collect Time: 06:47
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.002, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25175**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-123 Mens A102

Collect Date: 10/25/2016
Collect Time: 06:47
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25176**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-124 Womens A101

Collect Date: 10/25/2016
Collect Time: 06:49
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25177
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-125 Womens A101

Collect Date: 10/25/2016
Collect Time: 06:49
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25178**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-126 Girls E108

Collect Date: 10/25/2016
Collect Time: 06:50
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25179
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-127 Boys E110

Collect Date: 10/25/2016
Collect Time: 06:51
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25180**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-128 Mens Rm E111

Collect Date: 10/25/2016
Collect Time: 06:52
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25181**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-129 Womens Rm E111

Collect Date: 10/25/2016
Collect Time: 06:53
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25182**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-BF-130 Nurses BR

Collect Date: 10/25/2016
Collect Time: 06:54
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25183**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-131 Boys BR Across E203

Collect Date: 10/25/2016
Collect Time: 06:55
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25184**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-132 Boys BR Across E203

Collect Date: 10/25/2016
Collect Time: 06:55
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
 (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25185**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-133 Boys BR Across E203

Collect Date: 10/25/2016
Collect Time: 06:55
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25186
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-134 Mens BR E212

Collect Date: 10/25/2016
Collect Time: 06:56
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25187**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-135 Rm E214

Collect Date: 10/25/2016
Collect Time: 06:57
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25188
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-136 Prep Rm E214A

Collect Date: 10/25/2016
Collect Time: 06:58
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.12, 0.015, X, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25189**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-137 Rm E220 A

Collect Date: 10/25/2016
Collect Time: 06:59
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.007	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25190**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-138 Rm E220 B

Collect Date: 10/25/2016
Collect Time: 06:59
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25191**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-139 Rm E220 C

Collect Date: 10/25/2016
Collect Time: 06:59
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.017	0.015	X	mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25192**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-140 Rm E220 D

Collect Date: 10/25/2016
Collect Time: 06:59
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.010	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:


- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.


 John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25193**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-141 Rm E220 E

Collect Date: 10/25/2016
Collect Time: 07:00
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.012	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25194**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-142 Rm E220 F

Collect Date: 10/25/2016
Collect Time: 07:00
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25195**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-143 Rm E220 G

Collect Date: 10/25/2016
Collect Time: 07:00
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25197**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-144 Rm E220 H

Collect Date: 10/25/2016
Collect Time: 07:00
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.023	0.015	X	mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25198**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-145 Rm E220 I

Collect Date: 10/25/2016
Collect Time: 07:01
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.014	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25199**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-146 Rm E220 J

Collect Date: 10/25/2016
Collect Time: 07:01
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.010	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25200**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-147 Rm E220 K

Collect Date: 10/25/2016
Collect Time: 07:01
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.011	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
 (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25201**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-148 Rm E220 L

Collect Date: 10/25/2016
Collect Time: 07:01
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.009	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:


X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25202
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-149 Rm E220 M

Collect Date: 10/25/2016
Collect Time: 07:01
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.010, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1

Sample ID: AW25203
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-150 Rm E220 Teacher

Collect Date: 10/25/2016
Collect Time: 07:02
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.095, 0.015, X, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25204**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-151 Womens E222

Collect Date: 10/25/2016
Collect Time: 07:03
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25205**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-152 Girls E224

Collect Date: 10/25/2016
Collect Time: 07:04
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
 (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25206**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-153 Girls E224

Collect Date: 10/25/2016
Collect Time: 07:04
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25207**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-154 Girls E224

Collect Date: 10/25/2016
Collect Time: 07:04
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25208**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-155 Boys W210

Collect Date: 10/25/2016
Collect Time: 07:06
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1

Sample ID: AW25209
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-156 Boys W210

Collect Date: 10/25/2016
Collect Time: 07:06
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, M+, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25210
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-157 Boys W210

Collect Date: 10/25/2016
Collect Time: 07:06
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25211
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-158 Mens BR W212

Collect Date: 10/25/2016
Collect Time: 07:07
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.001, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25212**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-159 W214 Goggles

Collect Date: 10/25/2016
Collect Time: 07:08
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.009	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25213**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-160 W214 Goggles

Collect Date: 10/25/2016
Collect Time: 07:08
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.006	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25214**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-161 W214

Collect Date: 10/25/2016
Collect Time: 07:09
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25216**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-162 W214

Collect Date: 10/25/2016
Collect Time: 07:09
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25217**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-163 W214

Collect Date: 10/25/2016
Collect Time: 07:09
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25218**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-164 W214

Collect Date: 10/25/2016
Collect Time: 07:09
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.021	0.015	X	mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25219**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-165 W214

Collect Date: 10/25/2016
Collect Time: 07:09
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25220**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-166 W214A Prep Rm

Collect Date: 10/25/2016
Collect Time: 07:11
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.020	0.015	X	mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:


X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25221**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-167 W220 by Teacher

Collect Date: 10/25/2016
Collect Time: 07:12
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.20	0.015	X	mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25222**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-CF-168 W220 by Teacher

Collect Date: 10/25/2016
Collect Time: 07:12
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.11	0.015	X	mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25228**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-174 Womens BR W222

Collect Date: 10/25/2016
Collect Time: 07:15
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015	M+	mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25229**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-175 Girls BR W224 L

Collect Date: 10/25/2016
Collect Time: 07:16
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25230**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-176 Girls BR W224 M

Collect Date: 10/25/2016
Collect Time: 07:16
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25231**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-2-BF-177 Girls BR W224 R

Collect Date: 10/25/2016
Collect Time: 07:16
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
 (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25233**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-CF-178 W102 Art Rm

Collect Date: 10/25/2016
Collect Time: 07:18
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25234**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-CF-179 W102 Art

Collect Date: 10/25/2016
Collect Time: 07:18
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:


- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25235**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-CF-180 W104 Ind. Arts

Collect Date: 10/25/2016
Collect Time: 07:19
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25236**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: JHS-1-CF-181 W106

Collect Date: 10/25/2016
Collect Time: 07:20
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
 (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25237**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-182 Mens T103

Collect Date: 10/25/2016
Collect Time: 07:21
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25238**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-183 Mens T103

Collect Date: 10/25/2016
Collect Time: 07:21
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: AW25239
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-184 Mens T103

Collect Date: 10/25/2016
Collect Time: 07:21
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25240**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-185 Womens BR T104

Collect Date: 10/25/2016
Collect Time: 07:23
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25241**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-186 Womens BR T104

Collect Date: 10/25/2016
Collect Time: 07:23
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25242**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-BF-187 Womens BR T104

Collect Date: 10/25/2016
Collect Time: 07:23
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25243**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-CF-188 T119

Collect Date: 10/25/2016
Collect Time: 07:24
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1

Sample ID: AW25245
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-CF-189 T114

Collect Date: 10/25/2016
Collect Time: 07:25
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 12/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/19/2016 Page 1 of 1
Sample ID: **AW25246**
Date Received: 10/27/2016
Time Received: 10:13
Date Finalized: 12/19/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 215 Harry Howard Ave, Hudson- Jr-Sr High
Sample Pt: HS-1-CF-190 T112

Collect Date: 10/25/2016
Collect Time: 07:26
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 22 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	12/16/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.